



1. REFER TO SHEET \$0.01 THROUGH \$0.04 FOR GENERAL NOTES AND STRUCTURAL SPECIFICATIONS.
2. ALL ROOF SLOPES AS SHOWN ARE TO BE REVIEWED AND APPROVED BY THE ROOFING SUPPLIER.
3. CRICKETS ARE TO BE PROVIDED WITH SUFFICIENT DEPTH AND SLOPE TO ACCOMMODATE PROPER DRAINAGE ON ROOF AT ALL EQUIPMENT AND PENETRATIONS.
4. COORDINATE ALL ROOF PENETRATIONS WITH MECHANICAL DRAWINGS.
5. ALL STORM DRAWINGS, INCLUDING CLEANOUTS AND EXTERIOR SPORTS TO BE LOCATED AWAY FROM SIDEWALK/WALKWAYS
6. SEE STRUCTURAL PLAN SHEETS FOR WALL AND DECK DIMENSIONS
7. SEE SHEET \$7.01 FOR ROOFING DETAILS.

1. TPO MEMBRANE OVER 2" LW INSULATING CONC W/ 3" MIN TAPERED INSULATING RIGID INSULATION ON LW INSULATED CONC FILLED STRUCTURAL METAL DECK. SEE S2.02 FOR STRUCTURAL DECK REQUIREMENTS. ROOF TO COMPLY WITH FM GLOBAL ASSEMBLY NO. 262577-0-244170.
2. ROOF AND OVERFLOW DRAINS. SEE MECH DRAWINGS AND DETAIL 2/S7.01
3. CURB TO BE PROVIDED AT EVAPORATOR CUT OUTS. SEE DETAIL 5/S7.01

[illegible]

**PRELIMINARY
NOT FOR
CONSTRUCTION
2 JULY 2025**

4990 Royal Gulf Circle
Fort Myers, FL 33966
Ph: 239.768.1778, Fax: 239.210.2168
<http://www.veiglobal.com>



Title: AMALGAMATED SUGAR COMPANY EVAPORATOR PROJECT
ROOFING AND DRAINAGE PLAN



AMALGAMATED SUGAR COMPANY
2320 ORCHARD DRIVE EAST
TWIN FALLS, ID 83301

Date: 07/01/2025
Chkd By: S. WILSON
Dsgn By: D. VIELE

Project:	E24140	Revision:
Dwg:	S2.12	